



**SANTA MARIA FIRE DEPARTMENT –  
FIREWORKS STAND INSPECTION CHECKLIST**

314 W. Cook Street #8, Santa Maria, CA 93458-5557 ▪ (805) 925-0951 Ext. 8533

The Fire Inspector will be conducting random inspections of your stand looking for the following Fire Department requirements. Please take a few minutes and perform a self-inspection and make the necessary corrections before you open your stand.

ORGANIZATION: \_\_\_\_\_ DATE: \_\_\_\_\_

LOCATION: \_\_\_\_\_

REQUIREMENTS	OK
Location of property acceptable.	
Weeds and debris cleared a minimum of 25' from the stand.	
Minimum of (2) signs prohibiting sales to persons under 16 years of age, posted on the front exterior of the booth.	
Minimum of (2) "No Smoking" signs posted on each side of the booth. <b>Signs must be posted in Spanish and English.</b>	
Minimum of (2) penalty notices signs posted on the front exterior of the booth. Signs must be printed on 8 ½" X11" yellow paper. <b>Signs must be in posted in Spanish and English.</b>	
Hours of fireworks usage signs posted on all sides of the booth. <b>Signs must be in posted in Spanish and English.</b>	
Local permit posted.	
State Fire Marshal permit posted.	
Ample supply of penalty notices and fireworks usage handouts to be given with each purchase. <b>Handouts must be in Spanish and English.</b>	
No parking within 25' of stand.	
Fireworks stand instruction sheet posted.	
2A 2-½ gallon water fire extinguisher.	
Ability to secure stand doors from the inside using a slide bolt through wood <b>not additional hasp locks.</b>	
The use of padlocks or similar locking devices during operating hours is prohibited.	
Electrical connections acceptable.	
Aisle passageways clear.	

**PLEASE CALL IF YOU HAVE ANY QUESTION OR COMMENTS REGARDING THIS FORM.  
THIS INSPECTION FORM IS FOR YOUR USE ONLY.**