



**CITY OF SANTA MARIA
NORTH BLOSSER ROAD IMPROVEMENT PROJECT**



BID NO. 2020/05

ORIGINAL BID OPENING DATE: 03/09/2021

ADDENDUM NO. - 1 -


Enclosed please find one (1) copy of Addendum No. -1 - dated **March 3, 2021**. Please confirm receipt of Addendum No. - 1 - by signing and returning this acknowledgment of receipt WITH YOUR BID to be submitted on **03/09/21**.

**ITEM NO. 1 - IDENTIFIED AS ADDENDUM NO. - 1 -, DATED 03/03/21:
REQUESTS FOR INFORMATION: Questions and Answers**

**ITEM NO. 2 - IDENTIFIED AS ADDENDUM NO. - 1 -, DATED 10/14/2020:
REPLACE PAGE 2, IN ITS ENTIRETY, REVISIONS (in red text)**

**ITEM NO. 3 - IDENTIFIED AS ADDENDUM NO. - 1 -, DATED 10/14/2020:
REPLACE PAGE 200, IN ITS ENTIRETY, REVISIONS (in red text)**

**ITEM NO. 4 - IDENTIFIED AS ADDENDUM NO. - 1 -, DATED 10/14/2020:
REPLACE PAGE 202, IN ITS ENTIRETY, REVISIONS (in red text)**

for 

KEVIN P. MCCUNE, P.E.
DIRECTOR OF PUBLIC WORKS/
CITY ENGINEER

**Receipt of Addendum No. - 1 -, City of Santa Maria, BID NO. 2020/05, NORTH
BLOSSER ROAD IMPROVEMENT PROJECT is hereby acknowledged.**

Contractor

Date

REQUESTS FOR INFORMATION: Questions and Answers

1. Bid Item 4 1/2 AC - 366 ton. Is this correct? I don't see any overlay sections, just patch back ramps, cross-gutter/spandrel. Please let me know.

ANSWER: *BID ITEM NO. 4 – HOT MIX ASPHALT CONCRETE (TYPE A) is the pay item for all HMA material to be used on the project including material for AC Berm / Dike. BID ITEM NO. 5 – PLACE HOT MIX ASPHALT BERM (TYPE A) includes the furnishing of all tools, equipment, labor and materials required to complete the work with the exception of the hot mix asphalt material which is paid for in Bid Item NO. 4 - HOT MIX ASPHALT CONCRETE (TYPE A).*

2. What pay item covers the patch batch of 2' of asphalt for ramps, cross-gutters, and spandrels?

ANSWER: *BID ITEM NO.7 – P.C.C. SPANDREL, BID ITEM NO. 8 – P.C.C. CROSS-GUTTER, and BID ITEM NO. 9 – P.C.C ADA RAMP include the furnishing of all tools, equipment, labor, and materials to accomplish the removal and replacement of the patch back 2-foot section of asphalt pavement with the exception of the hot mix asphalt material which is paid for in Bid Item NO. 4 - HOT MIX ASPHALT CONCRETE (TYPE A).*

3. Will the City provide survey for the project?

ANSWER: *No, the City will not provide survey for the project. The City can provide CAD files for the project to the contractor by request once under contract.*

4. On Sheet LD-1 (26 of 26) Detail 2, it shows the header board being installed with 4" x 4" galvanized steel ell brackets with screws at 18" O.C., however, pg 200 of the special provisions say to install the header by core drilling pilot holes and driving steel stakes through the asphalt. Please advise which method is acceptable.

ANSWER: *The method indicated on the plans, Sheet LD-1 (26 of 26) Detail 2 shall be used for installation of the header boards. The applicable pages for Special Provisions for Bid Items No. 19 and 20 have been modified accordingly and are part of this addendum.*

5. Will the City require the slurry seal machines to be calibrated?

ANSWER: *Yes. This project follows Caltrans Specifications with regarding to the slurry seal placement. Caltrans requires calibration of the equipment. The City is not able to deviate from this requirement as specified.*

DOCUMENT 00022

Item No. 2 Per
Addendum Dated
03/03/21

NOTICE INVITING BIDS

CITY OF SANTA MARIA, CA

SEALED BIDS will be received at the offices of the City Clerk, City Hall, 110 East Cook Street (~~Room 6~~ Room 3), Santa Maria, California 93454, until

2:00 p.m. local time, 03/09/2020

at which time they will be publicly opened and read for performing work as follows:

Construction of the BID NO. 2020/05, NORTH BLOSSER ROAD IMPROVEMENT PROJECT, consists of roadway medians, landscaping, irrigation, signage, striping and bikeway improvements, and all work necessary to render the facility complete and operational.

The City of Santa Maria affirms that in any contract entered into pursuant to this advertisement, disadvantaged business enterprises will be afforded full opportunity to submit bids in response to this invitation. The Disadvantaged Business Enterprise (DBE) contract goal is eight percent (8%).

For the purchase of drawings, specifications and other bidding documents, contact the offices of the City Engineer at (805) 925-0951 ext. 2225. The price of the documents are \$75.00, which cost is NON-REFUNDABLE regardless of whether the drawings, specifications and other bidding documents are returned or not. Upon receipt of your payment, the documents will be sent to you using an overnight delivery service. Until further notice, copies of drawings, specifications, and other bidding documents are not available for review at the offices of the City Engineer.

Requests for information or clarification must be submitted **IN WRITING** and received in the Department of Public Works no later than 5:00 p.m. on Tuesday, **03/02/2021**. Requests may be submitted via e-mail to: eriddiough@cityofsantamaria.org

The Design Engineer has calculated an estimate of probable construction costs for this project. The City does not wish to publicize the engineer's estimate of the project cost since this information may tend to influence the number and nature of bids received. However, for bidder's convenience, the City will publicize that the engineer's estimate for the base bid falls within a range of \$575,000 and \$675,000.

Bids shall be executed on the forms provided in the book of bidding documents and in accordance with the instructions contained therein. A separate, unbound, set of bid forms are provided for the bidders convenience.

Bid security, in an amount not less than 10 percent of the total bid dollar amount, is required

BID ITEM NO. 19 – DECORATIVE ROCK - BLUE /GRAY (6" THICK)

1. DESCRIPTION

This work includes the furnishing of all tools, equipment, labor and materials required to accomplish all of the following work within the limits designated on the plans or as required by the Engineer in accordance with the Plans and Specifications.

This item includes installation of decorative rock. The work includes but is not limited to the following:

- a . Decorative Rock
- b . Plastic Header
- c . Plastic liner
- d. Wire mesh (drainage opening)

MATERIALS -

Decorative Rock: 1-1/2" x 3/4" clean, crushed, angular granite rock with distinctive blue/gray hue. (Santa Margarita by Hanson or approved equal). Gradation shall be such that no more than 3% is smaller than 1/2" based on supplier certified gradation curve/table. Contractor to submit bulk sample for City approval prior to installation.

2 x 6 Plastic Header: 2"x 6" Trex composite board or approved equal.

~~Stakes: Galvanized steel or plastic as indicated on Plans, 18" long~~

Plastic liner: minimum 10 mil polyethylene

Wire mesh: Galvanized steel, 12-gauge min, 1/2" max opening

INSTALLATION:

- a. Prior to installation of decorative rock, coordinate with other trades for the installation of asphalt berm where indicated on Drawings.
- b. Install plastic header for decorative rock, where indicated on the Drawings. Core drill pilot hole then drive steel stakes through existing asphalt.
- c. Place plastic liner with minimum of 12 inches of overlap between sections. Liner to extend all the way to flowline (edge) of berm. Overlaps shall allow for positive drainage over plastic towards berm and drainage openings. Spread decorative rock evenly to the level of required finish

BID ITEM NO. 20 – DECORATIVE ROCK - TAN (6" THICK)

Item No. 4 Per
Addendum Dated
03/03/21

1. DESCRIPTION

This work includes the furnishing of all tools, equipment, labor and materials required to accomplish all of the following work within the limits designated on the plans or as required by the Engineer in accordance with the Plans and Specifications.

This item includes installation of decorative rock. The work includes but is not limited to the following:

- a . Decorative Rock
- b . Wire mesh
- c . Plastic liner

MATERIALS -

Decorative Rock: 1-1/2" x 3/4" clean, crushed, angular granite aggregate with distinctive tan hue (Rocky Canyon by CalPortland or approved equal). Gradation shall be such that no more than 3% is smaller than 1/2" based on supplier certified gradation curve/table. Contractor to submit bulk sample for City approval prior to installation.

Wire mesh: Galvanized steel, 12-gauge min, 1/2" max opening

INSTALLATION:

Plastic Header ~~& Stakes~~: Installation of plastic header ~~and stakes~~ will be per Bid Item No. 19

- a. Prior to installation of decorative rock, coordinate with other trades for the installation of asphalt berm where indicated on Drawings.
- b. Place plastic liner with minimum of 12 inches of overlap between sections. Liner to extend all the way to flowline (edge) of berm. Overlaps shall allow for positive drainage over plastic towards berm and drainage openings. Spread decorative rock evenly to the level of required finish grade where indicated on the Drawings.

2. MEASUREMENT AND PAYMENT

BID ITEM NO. 20 – DECORATIVE ROCK - TAN (6" THICK) will be the number of cubic yards placed and will be paid at the contract unit price for each cubic yard acceptably installed in accordance with the Plans and Specifications. Such payment shall be full compensation for furnishing all labor, materials, tools, and equipment necessary to complete **BID ITEM NO. 20 – DECORATIVE ROCK - TAN (6" THICK)**.

*** END OF BID ITEM NO. 20 ***